

Certificate of Conformity

By the product certificate number:

No. 2622/0478-N-E1-CER

Issued to:

License holder: **Victron Energy B.V.**
De Paal 35, 1351JG, Almere, Netherlands

Trademark:



Contract number: 802190

It is certified that the product:

Type of generating unit: **Inverter/Charger with UPS functionality**

Models:	MultiPlus-II 48/8000/110-100 230V	MultiPlus-II 48/10000/140-100 230V	MultiPlus-II 48/15000/200-100 230V
Technical Data:			
Nominal power:	8 kVA / 6.4 kW	10 kVA / 8 kW	15.0 kVA / 12.0 kW
Nominal voltage:		AC input: 187-250 V _{ac} DC input: 38-66 V _{dc} AC output: 220-240 V _{ac} DC output: 48 V _{dc}	
Nominal frequency:		50 Hz	
Firmware version:	2621502	2627502	2619502
Number of phases:		Single Phase (L/N/PE)	
Isolation Transformer:		Yes	

Is in compliance with the standard:

IEC 62116: 2014 "Utility-Interconnected photovoltaic inverters – Test procedure of islanding prevention measures."

The above-mentioned generating unit is certified according to the SGS internal procedure PE.T-ECPE-18 based on the requirements of the UNE-EN ISO/IEC 17065.

This certificate cancels and supersades certificate no. 2622/0478-N-CER.

First issued on: 02nd February 2024.

This certificate is valid until: 23rd March 2028.

Madrid, 02nd February 2024

Daniel Arranz Muñiz
Certification Manager

